



DEPARTMENT OF PUBLIC WORKS

Richard Paul Jr.
Director of Public Works

13600 Juneau Boulevard
Elm Grove, Wisconsin 53122-1679

(262) 782-6700 Fax (262) 782-8714

E-Mail rpauljr@elmgrovewi.org

May 20th, 2020

RE: Notice of Sanitary Sewer Overflows 5-17-2020

In compliance with the WDNR and the Village of Elm Grove Permit WI-SO654040-2, this serves as notification of a Sanitary Sewage Overflow Notification (SSO) which occurred as a result of the intense rainfalls the Village experienced between 5-17-2020 through 5-19-2020.

Total concentrated rainfalls were recorded at the nearby MMSD rain gauge (located at 12308 W. Underwood Parkway) at 3.97 inches between 5/17/-5/18/2020. Local concentrations of rainfall may have been higher at the specific locations of the overflow sites.

The following locations were bypassed:

SW corner of Juneau Blvd & Elm Grove Rd due to sanitary main defect

Watertown Plan Rd at Fox Creek Ct

Post bypass inspections indicated there was no health hazards existing.

Richard Paul, Jr.

Richard Paul, Jr.
Public Works Director
Village of Elm Grove